

Fire Extinguisher Visual Inspection Checklist

Monthly visual readiness form for extinguisher access, condition, tag, and follow-up.

Company/Site	Location / ID	Extinguisher Type
Date	Inspector	Next Review Due

Inspection items

Check item	OK	Not OK	Notes / action
Extinguisher is in the assigned location, visible, and reachable without blocked access.			
Cabinet, bracket, strap, signage, and mounting position appear secure and usable.			
Pressure gauge or status indicator is in the acceptable range where applicable.			
Pin, tamper seal, hose, nozzle, handle, and label are present and show no obvious damage.			
Inspection tag or service label is present, readable, and consistent with site procedure.			
Cylinder shows no obvious corrosion, denting, leakage, discharge residue, or other visible concern.			
Any missing, used, blocked, damaged, or out-of-range extinguisher is recorded for prompt follow-up.			

Finding / service action

Record the extinguisher location or ID, condition found, access issue, service request, and completion date.

Inspector signature / date	Reviewer or service owner / date
-----------------------------------	---